



Refer to your HERS Feature Summary on the CF1R, located on CF1R typ. page 3

HERS FEATURE SUMMARY
The following is a summary of the features that must be field-verified by a certified HERS Rater as a condition for meeting the modeled energy performance for this computer analysis. Additional detail is provided in the building tables below. Registered CF2Rs and CF3Rs are required to be completed in the HERS Registry

## When to Call Your HERS Rater

Project Phase	HERS Inspection to be Verified at Installation	Task to Verify	Task Complete (HERS Rater Initials)	Date Verified
<b>Kick Off Meeting with Trades &amp; Builder</b>	<b>Review all HERS measures selected for the project</b>	<b>Failure to do so may result in added cost and schedule delays</b>		
<b>Foundation</b>	Quality Insulation Installation	<ul style="list-style-type: none"> <li>Perimeter/Under slab Insulation</li> <li>Raised Floor</li> </ul>		
<b>Framing</b>	Quality Insulation Installation	<ul style="list-style-type: none"> <li>Exterior Corners</li> <li>Tubs, Fireplaces, Stairs</li> </ul>		
<b>Insulation</b>	Quality Insulation Installation	<ul style="list-style-type: none"> <li>R-value specified</li> <li>Air sealing, incl. electrical penetrations</li> <li>Fan penetrations</li> </ul>		
	Reduced Building Air Leakage	<ul style="list-style-type: none"> <li>Blower door test</li> </ul>		
<b>Plumbing</b>	Pipe insulation credit	<ul style="list-style-type: none"> <li>R-Value</li> </ul>		
	Recirculation System	<ul style="list-style-type: none"> <li>Demand Control Type</li> <li>Location of sensors/control</li> </ul>		
<b>HVAC</b>	IAQ Fan (Exhaust/Balanced/Supply)	<ul style="list-style-type: none"> <li>CFM matches CF1R</li> <li>Type matches CF1R</li> </ul>		
	Kitchen Hood	<ul style="list-style-type: none"> <li>CFM &amp; HVI Certified</li> </ul>		
	Visual Inspection of HVAC System in Conditioned Space	<ul style="list-style-type: none"> <li>Location of Unit</li> <li>Location of Ducts &amp; R-Value</li> <li>Efficiencies</li> </ul>		
	Variable Capacity Heat Pump (VCHP)	<ul style="list-style-type: none"> <li>Refer to HERS Feature Summary, items showing (SC3.X)</li> </ul>		
	Duct Leakage Testing	<ul style="list-style-type: none"> <li>Sealed boots</li> <li>Meets the leakage requirement</li> <li>Efficiencies of Equipment</li> </ul>		
	Low Leakage Air Handler	<ul style="list-style-type: none"> <li>Unit Specification confirmed</li> <li>&lt;5% credit taken confirmed</li> </ul>		

Questions? Call or text an Energy Code Coach at **(805) 220-9991**

